

CERTIFICATE OF COMPLIANCE

Certificate Number 20181005-E194432
Report Reference E194432-20071011
Issue Date 2018-OCTOBER-05

Issued to: BUD INDUSTRIES
4605 E 355TH ST
WILLOUGHBY OH 44094-4629

This is to certify that representative samples of INDUSTRIAL CONTROL PANELS
Enclosures, Industrial Control Panels, Series SNB and SNC.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508A, Standard for Industrial Control Panels
C22.2 No. 14-13, Standard for Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20181005-E194432
Report Reference E194432-20071011
Issue Date 2018-OCTOBER-05

File E194432 Vol. 5 Sec. 1 Page 1 Issued: 2007-10-11
and Report Revised: 2018-11-15

DESCRIPTION

PRODUCT COVERED:

USL, CNL Enclosures, Industrial Control Panels, Series SNB and SNC.

GENERAL:

The enclosures are constructed in accordance with the Standard for Industrial Control Panels, UL 508A, and with the construction as described to the particular type of the enclosure in this Report.


RATINGS:

- * SNB and SNB-SS Series - Type 1, 2, 4, 4X, 12, and 13.
- SNC and SNC-SS Series - Type 1, 2, 4, 4X, 12 and 13.

TECHNICAL CONSIDERATIONS (NOT FOR FIELD REPRESENTATIVE'S USE):

Products designated USL have been investigated using requirements contained in the Standard for Industrial Control Panels, UL508A.

Products designated CNL have been investigated using requirements contained in CAN/CSA C22.2 No. 14 - M2005, Industrial Control Equipment, CAN/CSA C22.2 No. 94-M95.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

